



**Note:**  
 This spec is to be used  
 in conjunction with the  
 general 3phs pad spec.

1. 2/0 BARE COPPER GROUNDING WIRE TO BE PLACED UNDER PAD BEFORE PAD IS POURED.
2. WIRE TO BE BONDED TO GROUND RODS WITH HEAVY BOLTED CLAMP.
3. LEAVE SLACK IN BARE CU GROUND WIRE IN HIGH AND LOW SIDE CAVITIES FOR P.E.S. TO ATTACH TO.
4. INSTALL CONDUIT GROUNDING BUSHING FOR EACH STEEL PRIMARY CONDUIT.
5. ALL MATERIAL ON THIS SHEET TO BE FURNISHED BY CUSTOMER UNLESS OTHERWISE SPECIFIED.

### PULASKI ELECTRIC SYSTEM TYPICAL FOR CONCRETE PAD

Location:		
Trans. size 1000KVA	Gal. oil	LB.
/ 1500KVA / 2000KVA	Manufacture date	
S/N		
Voltage 277/480		Taps no
%Z 1.5	Fault Current	